



UST Field Notice of Non-compliance

No. 1148

The Environmental Protection Agency (EPA) is responsible for the enforcement of underground storage tank (UST) laws that protect human health and the environment. Pursuant to federal regulation at 40 CFR Part 280, during an inspection on

8-8-08

(Date)

the following items of UST non-compliance were observed at your facility:

① Description: 280.44(a) Failure to provide annual line leak detector testing for pressurized piping	Correction Required: Conduct and provide test results for automatic line leak detectors	Deadline: 9-15-08
② Description: 280.44(b) Failure to provide annual testing of pressurized piping	Correction Required: Conduct and provide test results for all pressurized lines	Deadline: 9-11-08
③ Description:	Correction Required:	Deadline:
④ Description:	Correction Required:	Deadline:

WARNING

The EPA wishes to work cooperatively with you as the owner and/or operator of this facility to resolve the violation(s) listed above at this time. Therefore, no penalty will currently be assessed. However, if you fail to complete the above noted compliance task(s) before the listed deadline(s), you will become subject to citation and/or formal enforcement action. Such enforcement actions mandate compliance and carry monetary penalties as high as \$11,000 for every day of continued violation on each underground tank.

Notify your EPA contact person (listed below) immediately if you are unable to perform the required actions within the specified dates.

EPA Inspector	Facility Information	
Name: Jim Greeves	Name of Facility: Soldotna Y Chevron	Facility ID #: AK 518
Office Address: EPA-WA H&A op office 300 Desmond Dr SE St 102 Lacey WA 98503	Address: 44024 Sterling Hwy Soldotna AK 99669	
Phone: 360-753-8072 / PA+ 8080	Contact: Mark Rozak / Fred Hammon	Phone: 907 / 262-4513
Signature: Jim Greeves	Signature: Mark Rozak (Signature acknowledges receipt only)	